

Andhra Pradesh State FiberNet Limited (APSFL)

**Request for Proposal (RFP) for Supply, Installation & Commissioning of DG (Diesel Generator) at
Identified District Headquarters (DHQs) in AP**

Ref. No. - APSFL/DHQ Equipment/210/2017-05, dated 20/09/2017

Corrigendum - 1, Dated-27/09/2017

Bidders may please note that this Corrigendum document is part of the RFP. The items listed in this Corrigendum will supersede the corresponding clauses in RFP.

S. No.	Section No.	Page	Clause in RFP	Revised Clause
		No.		
1	Annexure X – Technical Specifications	30	Make: Cummins / Kirloskar Green / Perkins / Caterpillar. Diesel engine Shall be direct injection water cooled, 4stroke, 1500 rpm of suitable BHP capable of giving above mentioned output of alternator. Engine will be fitted with all the required accessories. The average load factor of the engine over period of 24 hours shall be 0.80 for prime power output. The engine shall confirm to IS: 10000/ISO, 3046/BS, 649/BS 5514 amended up to date.	Make: Cummins / Kirloskar Green / Perkins / Caterpillar / Equivalent Brands. Diesel engine Shall be direct injection water cooled, 4stroke, 1500 rpm of suitable BHP capable of giving above mentioned output of alternator. Engine will be fitted with all the required accessories. The average load factor of the engine over period of 24 hours shall be 0.80 for prime power output. The engine shall confirm to IS: 10000/ISO, 3046/BS, 649/BS 5514 amended up to date.